CCS
Collins Combustion Services

Instrument Calibration Form

895 Tralee Ct, Gurnee IL 60031 | dcollins@collinscombustion.com | 847.477.8623

Customer	Sample	***Job No***	061914-00003	***Unit ID***	
Location		***Svc. Rep***	Darrell Collins	***Date***	
Address		***Title***	Field Service Engineer		
Address		***Phone***	847.477.8623		

Tag/Item	***Combustion Crontrol Device*** Transmitter / Device	Device Mfr	Part ID	Last Calib	Cur Calib	Range AF	Range AL	Applied	As Found	As Left	Dampening / Comments
	Air Flow Transmitter	Rosemount	3051	05/05/13	05/15/14	0-25"wc	0-25"wc	00.0"	00.6"	00.0"	2sec / zeroed
								12.5"	13.1"	12.5"	
								25.0"	25.6"	25.0"	
	Gas Flow Transmitter	Rosemount	3051	05/05/13	05/15/14	0-250"wc	0-250"wc	000.0"	000.0"	000.0"	2sec / zeroed
								125.0"	125.0"	125.0"	
								250.0"	250.0"	250.0"	
	Gas Flow Control Valve	Fisher	V Ball	05/05/13	05/15/14	0-100%	0-100%	0%	5%	0%	Zeroed and Spanned
								50%	45%	50%	
								100%	80%	100%	